

CLAIRIFY¹

QUANTUM DISINFECTION™



DISINFECTION

- removes more than 99.99% of bacteria from the water

WATER FLOWS

4 L/min

PERFORMANCE

- water volume: more than 56,000 liters of use
- contains high quality coconut shell GAC that reduces:
 - sediment, chlorine, odor and organics

CERTIFICATIONS

Quantum Disinfection™ is:

- a NSF Certified Component to NSF/ANSI 42 for material requirements only (Certificate #: C0292640-01)
- tested by IAPMO to NSF/ANSI 61 (Certificate #: 23033)
- Certified MOH - China (Certificate #: 2015KF2513)

NO CHEMICALS. NO POWER. NO PATHOGENS



Item Part Number	CT01
Applications	Point-of-Use
Power Requirements	None
Quantity of QD ceramics *	70 grams
Maximum Flow	4 L/min
System Dimensions	30 x 8 cm
Minimum - Maximum Pressure	1.4 - 8.6 bar
Capacity	56,000 litres
Water Temperature	5 - 38 °C
Inlet/Outlet Connection **	3/8 inch - QC (push in)


* The system contains:


- 70 grams of QD ceramics
- 350 grams of Granular Activated Carbon

** The 3/8 inch inlet and outlet connections are changeable



Claire Technologies, LL7
Claire Technologies Manufacturing, Inc"

 sales@clairify-quantum-disinfection.eu

 <https://clairify-quantum-disinfection.eu/>